











NO	RUANGAN/ POSISI	JUMLAH		WAKTU PEMAKAIAN												LUAS (m ²)		
		LM		07.00 - 09.00		09.00 - 11.00		11.00 - 13.00		13.00 - 15.00		15.00 - 18.00		18.00 - 20.00			20.00 - 07.00	
		LM	STU	LM	STU	LM	STU	LM	STU	LM	STU	LM	STU	LM	STU		LM	STU
1	JKSG OFFICE	8	1	4	1	4	1	4	1	4	1	8	1	8	1	0	0	23.04
2	IGOV OFFICE	10	1	10	1	10	1	10	1	10	1	4	1	4	1	0	0	28.8
3	IPIEF OFFICE	8	1	8	1	8	1	8	1	8	1	8	1	8	1	0	0	23.04
4	IPIREL OFFICE	10	1	8	1	4	1	4	1	4	1	0	0	0	0	0	0	28.8
5	IPOLS VISITING PROFESOR	8	1	4	0	2	0	2	0	2	0	2	0	2	0	0	0	23.04
6	IPOLS OFFICE	10	1	8	1	4	1	4	1	4	1	0	0	0	0	0	0	28.8
7	STUDY HALL IPIREL	18	2	10	2	10	2	10	2	10	2	10	2	10	2	0	0	51.84
8	OPERATOR	8	1	2	0	2	0	2	0	2	0	2	1	2	0	0	0	23.04
9	SECURITY	2	0	2	0	2	0	2	0	2	0	2	0	2	0	0	0	5.76
10	R. PT BUHARUM	8	1	4	1	4	1	4	1	4	1	0	0	0	0	0	0	23.04
11	R. MTCC	12	1	6	1	6	1	6	1	6	1	0	0	0	0	0	0	34.56
12	TU.MANAGEMENT KEPERAWATAN	18	2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	51.84
13	R. KULIAH PROFESI APOTEKER	18	2	0	1	0	1	0	0	0	0	0	0	0	0	0	0	51.84
14	STUDY HALL- A	12	1	6	1	6	1	6	1	6	1	12	1	12	1	0	0	34.56
15	STUDY HALL- B	12	1	6	1	6	1	6	1	6	1	0	0	0	0	0	0	34.56
16	STUDY HALL-C	18	2	0	0	6	2	6	2	6	2	0	0	0	0	0	0	51.84
17	IPAcc OFFICE	10	1	6	0	6	0	3	1	6	1	3	1	3	1	0	0	28.8
18	LOBI DAN LORONG (PLCE)	69	0	8	0	8	0	8	0	8	0	18	0	18	0	29	0	509.76
19	TOILET (PLCE)	28	12	28	12	28	12	28	12	28	12	28	12	28	12	28	12	109.44
	jumlah (BUAH)	287	32	120	24	112	26	113	26	122	26	97	20	75	14	57	12	1166.4
	JUMLAH (WATT)	12196	35392	5268	21312	4828	25088	4883	24832	5156	24832	3633	14272	2016	3712	1026	192	
JUMLAH PEMAKAIAN ENERGI LAMPU DAN STU (Wh)				53160	59832	59430	59976	53715	11456	15834								
TOTAL KONSUMSI ENERGI (kWh)		7521.672																
TOTAL NILAI IKE (kWh/m ² /bulan)		6.448621399																




NO	RUANGAN/POSISI	JUMLAH		WAKTU PEMAKAIAN																		LUAS
		LM	AC	07.00-09.00		09.00-11.00		11.00-13.00		13.00-15.00		15.00-18.00		18.00-20.00		20.00-07.00						
				LM	AC	LM	AC	LM	AC	LM	AC	LM	AC	LM	AC	LM	AC					
1	Ps.301	12	2	0	0	15	2	15	2	15	2	15	2	15	2	0	0	0	0	86.4		
2	Ps.302	12	2	15	2	15	2	15	2	15	2	15	2	15	2	0	0	0	0	86.4		
3	Ps.303	15	2	15	2	15	2	15	2	15	2	15	2	15	2	0	0	0	0	86.4		
4	Ps.304	15	2	15	2	15	2	15	2	15	2	15	2	15	2	0	0	0	0	86.4		
5	Ps.305	12	2	15	2	15	2	15	2	15	2	15	2	15	2	0	0	0	0	69.12		
6	Ps.306	12	2	15	2	15	2	15	2	15	2	15	2	15	2	0	0	0	0	69.12		
7	Ps.307	12	2	0	0	15	2	12	2	12	2	12	2	12	2	12	2	0	0	69.12		
8	Ps.308	12	2	0	0	0	0	12	2	12	2	12	2	12	2	12	2	0	0	69.12		
9	Ps.309	15	2	0	0	0	0	12	2	12	2	12	2	12	2	0	0	0	0	86.4		
10	Ps.310	15	2	0	0	0	0	12	2	12	2	12	2	12	2	0	0	0	0	86.4		
11	Ps.311	12	2	2	2	12	2	12	2	12	2	12	2	12	2	0	0	0	0	69.12		
12	Ps.312	12	2	12	2	12	2	12	2	12	2	12	2	12	2	0	0	0	0	69.12		
13	Pengajaran	3	1	3	1	3	1	3	1	3	1	3	1	3	1	0	0	0	0	25.92		
14	Transit dosen	3	1	3	1	3	1	3	1	3	1	3	1	3	1	0	0	0	0	25.92		
15	LOBI DAN LORING	51	0	0	0	0	0	0	0	0	0	0	0	42	0	42	4	0	0	544.33		
16	TOILET	28	12	28	12	28	12	28	12	28	12	28	12	28	12	28	12	0	0	109.44		
JUMLAH		241	38	123	28	163	32	166	34	85	26	142	24	94	20	0	0	0	0	1638.73		
JUMLAH WATT		5220	45952	2214	28352	2934	35392	2988	38912	1530	24832	2556	21312	1692	14272	0	0	0	0			
JUMLAH PEMAKAIAN ENERGI LAMPU DAN STU (Wh)				61132		76652		83800		52724		71604		31928		0						
TOTAL KONSUMSI ENERGI (kWh/bulan)		9068.16																				
TOTAL IBE (kWh/m ² /bulan)		5.533651059																				

NO	RUANGAN/ POSISI	JUMLAH		WAKTU PEMAKAIAN																								LUAS
		LM	AC	07.00-09.00		09.00-11.00		11.00-13.00		13.00-15.00		15.00-18.00		18.00-20.00		20.00-07.00												
				LM	AC	LM	AC	LM	AC	LM	AC	LM	AC	LM	AC	LM	AC											
1	Ps. 401	16	3	16	3	16	3	16	3	16	3	16	3	16	3	16	3	0	0	0	0	101.72						
2	Ps. 402	16	3	16	3	16	3	16	3	16	3	16	3	16	3	16	3	0	0	0	0	101.72						
3	Ps. 403	16	3	16	3	16	3	16	3	16	3	16	3	16	3	16	3	0	0	0	0	101.72						
4	Ps. 404	16	3	16	3	16	3	16	3	16	3	16	3	16	3	16	3	0	0	0	0	101.72						
5	Ps. 405	12	2	12	2	12	2	12	2	12	2	12	2	12	2	12	2	0	0	0	0	69.12						
6	Ps. 406	12	2	12	2	12	2	12	2	12	2	12	2	12	2	12	2	0	0	0	0	69.12						
7	Ps. 407	12	2	12	2	12	2	12	2	12	2	12	2	12	2	12	2	0	0	0	0	69.12						
8	LOBI DAN LORNG	49	0	9	0	9	0	9	0	9	0	9	0	15	0	15	0	15	6	0	0	440.64						
9	RUANG SEMINAR	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	207.36						
10	TOILET	28	12	28	12	28	12	28	12	28	12	28	12	28	12	28	12	28	12	0	0	109.44						
JUMLAH		177	30	137	30	137	30	137	30	137	30	137	30	143	30	75	24	0	0	0	0	1371.68						
JUMLAH WATT		3186	31872	2466	31872	2466	31872	2466	31872	2178	26592	2574	31872	1350	21312	0	0	0	0	0	0							
JUMLAH PEMAKAIAN ENERGI LAMPU DAN STU (Wh)				68676		68676		68676		68676		68676		57540		103338		45324		0								
TOTAL KONSUMSI ENERGI (kWh/bulan)		9893.52																										
TOTAL IKE (kWh/m ² /bulan)		7.212702671																										









REVISIONS

