



PT PLN (PERSERO) P3B JB
APP SALATIGA

**LAPORAN BEBAN PUNCAK TRAFU GARDU INDUK
PT PLN (PERSERO) P3B UPT SURAKARTA
BULAN : Januari 2012**

NO	GARDU INDUK	TRAFO			AMP NOM (A)	OCR Sett		BEBAN TERTINGGI							TEMPERATUR		
		NO	DAYA (MVA)	RATIO (KV)		A	KV	TGL	JAM	MW	MVAR	AMP INC	% In	Tegangan 20 KV		Windin g	Oil
														TRD	TTI		
1	KLATEN	I	30	150/20	866	150	150	11.01.2012	19	23.4	10.7	755	87.182448	21	20.6	64	53
2	KLATEN	II	30	150/20	866	150	150	27.01.2012	19	20.9	10.8	661	76.327945	21	20.8	62	62

Keterangan :



PT PLN (PERSERO) P3B JB
APP SALATIGA

**LAPORAN BEBAN PUNCAK TRAFU GARDU INDUK
PT PLN (PERSERO) P3B UPT SURAKARTA
BULAN : FEBRUARI 2012**

NO	GARDU INDUK	TRAFO			AMP NOM (A)	OCR Sett		BEBAN TERTINGGI							TEMPERATUR		
		NO	DAYA (MVA)	RATIO (KV)		A	KV	TGL	JAM	MW	MVAR	AMP INC	% In	Tegangan 20 KV		Windin g	Oil
														TRD	TTI		
1	KLATEN	I	30	150/20	866	150	150	09.02.2012	19	23.6	10.8	760	87.759815	21	20.6	66	55
2	KLATEN	II	30	150/20	866	150	150	10.02.2012	19	21.1	10.5	651	75.17321	21	21	63	62

Keterangan :



PT PLN (PERSERO) P3B JB
APP SALATIGA

**LAPORAN BEBAN PUNCAK TRAFU GARDU INDUK
PT PLN (PERSERO) P3B UPT SURAKARTA
BULAN : MARET 2012**

NO	GARDU INDUK	TRAFO			AMP NOM (A)	OCR Sett		BEBAN TERTINGGI							TEMPERATUR		
		NO	DAYA (MVA)	RATIO (KV)		A	KV	TGL	JAM	MW	MVAR	AMP INC	% In	Tegangan 20 KV		Windin g	Oil
														TRD	TTI		
1	KLATEN	I	30	150/20	866	150	150	27.03.2012	19	23.2	10.2	760	87.759815	21	20.3	63	52
2	KLATEN	II	30	150/20	866	150	150	27.03.2012	19	19.4	8.8	630	72.748268	21	20.3	60	60

Keterangan :



PT PLN (PERSERO) P3B JB
APP SALATIGA

**LAPORAN BEBAN PUNCAK TRAFU GARDU INDUK
PT PLN (PERSERO) P3B APP SALATIGA
BULAN : APRIL 2012**

NO	GARDU INDUK	TRAFO			AMP NOM (A)	OCR Sett		BEBAN TERTINGGI							TEMPERATUR		
		NO	DAYA (MVA)	RATIO (KV)		A	KV	TGL	JAM	MW	MVAR	AMP INC	% In	Tegangan 20 KV		Windin g	Oil
														TRD	TTI		
1	KLATEN	I	30	150/20	866	150	150	18.04.2012	19	24,4	11	775	89.491917	21	20.5	65	53
2	KLATEN	II	30	150/20	866	150	150	10.04.2012	19	21,4	10	641	74.018476	21	21	65	65

Keterangan :



PT PLN (PERSERO) P3B JB
APP SALATIGA

**LAPORAN BEBAN PUNCAK TRAFU GARDU INDUK
PT PLN (PERSERO) P3B APP SALATIGA
BULAN : MEI 2012**

NO	GARDU INDUK	TRAFO			AMP NOM (A)	OCR Sett		BEBAN TERTINGGI							TEMPERATUR		
		NO	DAYA (MVA)	RATIO (KV)		A	KV	TGL	JAM	MW	MVAR	AMP INC	% In	Tegangan 20 KV		Windin g	Oil
														TRD	TTI		
1	KLATEN	I	30	150/20	866	150	150	31.05.2012	19	23.3	10.3	735	84.872979	21	21	63	54
2	KLATEN	II	30	150/20	866	150	150	04.05.2012	19	19.9	9.4	619	71.47806	21	21	62	62

Keterangan :



PT PLN (PERSERO) P3B JB
APP SALATIGA

**LAPORAN BEBAN PUNCAK TRAFU GARDU INDUK
PT PLN (PERSERO) P3B APP SALATIGA
BULAN : JUNI 2012**

NO	GARDU INDUK	TRAFO			AMP NOM (A)	OCR Sett		BEBAN TERTINGGI							TEMPERATUR		
		NO	DAYA (MVA)	RATIO (KV)		A	KV	TGL	JAM	MW	MVAR	AMP INC	% In	Tegangan 20 KV		Windin g	Oil
														TRD	TTI		
1	KLATEN	I	30	150/20	866	150	150	20.06.2012	19	23.6	10.6	750	86.605081	21	20	66	56
2	KLATEN	II	30	150/20	866	150	150	21.06.2012	19	16.5	7.5	522	60.277136	21	20	60	60

Keterangan :



PT PLN (PERSERO) P3B JB
APP SALATIGA

**LAPORAN BEBAN PUNCAK TRAFU GARDU INDUK
PT PLN (PERSERO) P3B APP SALATIGA
BULAN : JULI 2012**

NO	GARDU INDUK	TRAFO			AMP NOM (A)	OCR Sett		BEBAN TERTINGGI							TEMPERATUR		
		NO	DAYA (MVA)	RATIO (KV)		A	KV	TGL	JAM	MW	MVAR	AMP INC	% In	Tegangan 20 KV		Windin g	Oil
														TRD	TTI		
1	KLATEN	I	30	150/20	866	150	150	20.07.2012	19	23.2	10.2	725	83.718245	20,7	20,7	61	51
2	KLATEN	II	30	150/20	866	150	150	16.07.2012	19	20.9	10.1	644	74.364896	21	21	57	57

Keterangan :



PT PLN (PERSERO) P3B JB
APP SALATIGA

**LAPORAN BEBAN PUNCAK TRAFU GARDU INDUK
PT PLN (PERSERO) P3B APP SALATIGA
BULAN : AGUSTUS 2012**

NO	GARDU INDUK	TRAFO			AMP NOM (A)	OCR Sett		BEBAN TERTINGGI							TEMPERATUR		
		NO	DAYA (MVA)	RATIO (KV)		A	KV	TGL	JAM	MW	MVAR	AMP INC	% In	Tegangan 20 KV		Windin g	Oil
														TRD	TTI		
1	KLATEN	I	30	150/20	866	150	150	13.08.2012	19	22.2	9.8	700	80.831409	20,7	20,7	60	50
2	KLATEN	II	30	150/20	866	150	150	10.08.2012	19	16.6	7.2	515	59.468822	21	21	60	60

Keterangan :



PT PLN (PERSERO) P3B JB
APP SALATIGA

LAPORAN BEBAN PUNCAK TRAFU GARDU INDUK
PT PLN (PERSERO) P3B APP SALATIGA
BULAN : SEPTEMBER 2012

NO	GARDU INDUK	TRAFO			AMP NOM (A)	OCR Sett		BEBAN TERTINGGI							TEMPERATUR		
		NO	DAYA (MVA)	RATIO (KV)		A	KV	TGL	JAM	MW	MVAR	AMP INC	% In	Tegangan 20 KV		Windin g	Oil
														TRD	TTI		
1	KLATEN	I	30	150/20	866	150	150	21.09.2012	19	22.9	10.7	705	81.408776	20,5	21	61	51
2	KLATEN	II	30	150/20	866	150	150	17.09.2012	19	16.5	7.6	508	58.660508	21	21	65	65

Keterangan :



PT PLN (PERSERO) P3B JB
APP SALATIGA

LAPORAN BEBAN PUNCAK TRAFU GARDU INDUK
PT PLN (PERSERO) P3B APP SALATIGA
BULAN : OKTOBER 2012

NO	GARDU INDUK	TRAFO			AMP NOM (A)	OCR Sett		BEBAN TERTINGGI							TEMPERATUR		
		NO	DAYA (MVA)	RATIO (KV)		A	KV	TGL	JAM	MW	MVAR	AMP INC	% In	Tegangan 20 KV		Windin g	Oil
														TRD	TTI		
1	KLATEN	I	30	150/20	866	150	150	09.10.2012	19	22.3	10.7	710	81.986143	20.7	20.7	65	54
2	KLATEN	II	30	150/20	866	150	150	30.10.2012	19	19.6	8.7	617	71.247113	21	21	65	65

Keterangan :



PT PLN (PERSERO) P3B JB
APP SALATIGA

**LAPORAN BEBAN PUNCAK TRAFU GARDU INDUK
PT PLN (PERSERO) P3B APP SALATIGA
BULAN : NOPEMBER 2012**

NO	GARDU INDUK	TRAFO			AMP NOM (A)	OCR Sett		BEBAN TERTINGGI								TEMPERATUR	
		NO	DAYA (MVA)	RATIO (KV)		A	KV	TGL	JAM	MW	MVAR	AMP INC	% In	Tegangan 20 KV		Windin g	Oil
														TRD	TTI		
1	KLATEN	I	30	150/20	866	150	150	09.11.2012	19	23.5	10.8	725	83.718245	20.7	20.7	64	53
2	KLATEN	II	30	150/20	866	150	150	09.11.2012	19	18	7.9	553	63.856813	21	20.7	58	58

Keterangan :



PT PLN (PERSERO) P3B JB
APP SALATIGA

**LAPORAN BEBAN PUNCAK TRAFU GARDU INDUK
PT PLN (PERSERO) P3B APP SALATIGA
BULAN : DESEMBER 2012**

NO	GARDU INDUK	TRAFO			AMP NOM (A)	OCR Sett		BEBAN TERTINGGI								TEMPERATUR	
		NO	DAYA (MVA)	RATIO (KV)		A	KV	TGL	JAM	MW	MVAR	AMP INC	% In	Tegangan 20 KV		Windin g	Oil
														TRD	TTI		
1	KLATEN	I	30	150/20	866	150	150	09.11.2012	19	23.5	10.8	725	83.718245	20.7	20.7	64	53
2	KLATEN	II	30	150/20	866	150	150	09.11.2012	19	18	7.9	553	63.856813	21	20.7	58	58

Keterangan :



PT PLN (PERSERO) P3B JB
APP SALATIGA

**LAPORAN BEBAN PUNCAK TRAFU GARDU INDUK
PT PLN (PERSERO) P3B APP SALATIGA
BULAN : JANUARI 2013**

NO	GARDU INDUK	TRAFO			AMP NOM (A)	OCR Sett		BEBAN TERTINGGI							TEMPERATUR		
		NO	DAYA (MVA)	RATIO (KV)		A	KV	TGL	JAM	MW	MVAR	AMP INC	% In	Tegangan 20 KV		Winding	Oil
														TRD	TTI		
1	KLATEN	I	30	150/20	866	150	150	31.01.2013	19	23,6	11	716	82.678984	20.7	20	61	51
2	KLATEN	II	30	150/20	866	150	150	19.01.2013	19	16,7	7,1	527	60.854503	21	20	59	59

Keterangan :



PT PLN (PERSERO) P3B JB
APP SALATIGA

**LAPORAN BEBAN PUNCAK TRAFU GARDU INDUK
PT PLN (PERSERO) P3B APP SALATIGA
BULAN : FEBRUARI 2013**

NO	GARDU INDUK	TRAFO			AMP NOM (A)	OCR Sett		BEBAN TERTINGGI							TEMPERATUR		
		NO	DAYA (MVA)	RATIO (KV)		A	KV	TGL	JAM	MW	MVAR	AMP INC	% In	Tegangan 20 KV		Winding	Oil
														TRD	TTI		
1	KLATEN	I	30	150/20	866	150	150	11.02.2013	19	23.3	10.7	727	83.949192	20.7	20.5	61	52
2	KLATEN	II	30	150/20	866	150	150	26.02.2013	19	20.6	9.7	614	70.900693	21	21	65	65

Keterangan :



PT PLN (PERSERO) P3B JB
APP SALATIGA

**LAPORAN BEBAN PUNCAK TRAFU GARDU INDUK
PT PLN (PERSERO) P3B APP SALATIGA
BULAN : MARET 2013**

NO	GARDU INDUK	TRAFO			AMP NOM (A)	OCR Sett		BEBAN TERTINGGI							TEMPERATUR		
		NO	DAYA (MVA)	RATIO (KV)		A	KV	TGL	JAM	MW	MVAR	AMP INC	% In	Tegangan 20 KV		Winding	Oil
														TRD	TTI		
1	KLATEN	I	30	150/20	866	150	150	06.03.2013	19	23.5	10.9	742	85.681293	20.7	20.7	61	53
2	KLATEN	II	30	150/20	866	150	150	22.03.2013	19	21.2	9.7	654	75.51963	21	21	62	62

Keterangan :



PT PLN (PERSERO) P3B JB
APP SALATIGA

**LAPORAN BEBAN PUNCAK TRAFU GARDU INDUK
PT PLN (PERSERO) P3B APP SALATIGA
BULAN : APRIL 2013**

NO	GARDU INDUK	TRAFO			AMP NOM (A)	OCR Sett		BEBAN TERTINGGI							TEMPERATUR		
		NO	DAYA (MVA)	RATIO (KV)		A	KV	TGL	JAM	MW	MVAR	AMP INC	% In	Tegangan 20 KV		Winding	Oil
														TRD	TTI		
1	KLATEN	I	30	150/20	866	150	150	30.04.2013	19	22.6	10.5	726	83.833718	20.7	20.7	63	53
2	KLATEN	II	30	150/20	866	150	150	26.04.2013	19	21.5	9.8	663	76.558891	21	21	65	65

Keterangan :



PT PLN (PERSERO) P3B JB
APP SALATIGA

**LAPORAN BEBAN PUNCAK TRAFU GARDU INDUK
PT PLN (PERSERO) P3B APP SALATIGA
BULAN : MEI 2013**

NO	GARDU INDUK	TRAFO			AMP NOM (A)	OCR Sett		BEBAN TERTINGGI							TEMPERATUR		
		NO	DAYA (MVA)	RATIO (KV)		A	KV	TGL	JAM	MW	MVAR	AMP INC	% In	Tegangan 20 KV		Winding	Oil
														TRD	TTI		
1	KLATEN	I	30	150/20	866	150	150	07.05.2013	19	23.3	10.7	763	88.106236	20.7	20.7	66	57
2	KLATEN	II	30	150/20	866	150	150	03.05.2013	19	21.6	9.7	660	76.212471	21	21	72	72

Keterangan :



PT PLN (PERSERO) P3B JB
APP SALATIGA

**LAPORAN BEBAN PUNCAK TRAFU GARDU INDUK
PT PLN (PERSERO) P3B APP SALATIGA
BULAN : JUNI 2013**

NO	GARDU INDUK	TRAFO			AMP NOM (A)	OCR Sett		BEBAN TERTINGGI							TEMPERATUR		
		NO	DAYA (MVA)	RATIO (KV)		A	KV	TGL	JAM	MW	MVAR	AMP INC	% In	Tegangan 20 KV		Winding	Oil
														TRD	TTI		
1	KLATEN	I	30	150/20	866	150	150	28.06.2013	19	22.3	9.9	732	84.526559	20.6	20.6	52	59
2	KLATEN	II	30	150/20	866	150	150	18.06.2013	19	21	9.1	636	73.441109	21	21	60	60

Keterangan :



PT PLN (PERSERO) P3B JB
APP SALATIGA

**LAPORAN BEBAN PUNCAK TRAFU GARDU INDUK
PT PLN (PERSERO) P3B APP SALATIGA
BULAN : JULI 2013**

NO	GARDU INDUK	TRAFO			AMP NOM (A)	OCR Sett		BEBAN TERTINGGI							TEMPERATUR		
		NO	DAYA (MVA)	RATIO (KV)		A	KV	TGL	JAM	MW	MVAR	AMP INC	% In	Tegangan 20 KV		Winding	Oil
														TRD	TTI		
1	KLATEN	I	30	150/20	866	150	150	22.07.2013	19	22.6	10	734	84.757506	20.8	20.8	61	59
2	KLATEN	II	30	150/20	866	150	150	26.07.2013	19	21.5	9.3	660	76.212471	21	21	61	60

Keterangan :



PT PLN (PERSERO) P3B JB
APP SALATIGA

**LAPORAN BEBAN PUNCAK TRAFU GARDU INDUK
PT PLN (PERSERO) P3B APP SALATIGA
BULAN : AGUSTUS 2013**

NO	GARDU INDUK	TRAFO			AMP NOM (A)	OCR Sett		BEBAN TERTINGGI							TEMPERATUR		
		NO	DAYA (MVA)	RATIO (KV)		A	KV	TGL	JAM	MW	MVAR	AMP INC	% In	Tegangan 20 KV		Winding	Oil
														TRD	TTI		
1	KLATEN	I	30	150/20	866	150	150	30.08.2013	19	22,4	9,6	734	84.757506	20.8	20.8	52	57
2	KLATEN	II	30	150/20	866	150	150	31.07.2013	19	21,8	9,8	668	77.136259	21	21	62	62

Keterangan :



PT PLN (PERSERO) P3B JB
APP SALATIGA

**LAPORAN BEBAN PUNCAK TRAFU GARDU INDUK
PT PLN (PERSERO) P3B APP SALATIGA
BULAN : SEPTEMBER 2013**

NO	GARDU INDUK	TRAFO			AMP NOM (A)	OCR Sett		BEBAN TERTINGGI							TEMPERATUR		
		NO	DAYA (MVA)	RATIO (KV)		A	KV	TGL	JAM	MW	MVAR	AMP INC	% In	Tegangan 20 KV		Winding	Oil
														TRD	TTI		
1	KLATEN	I	30	150/20	866	150	150	02.09.2013	19	23	10,2	740	85.450346	20.8	20.8	52	58
2	KLATEN	II	30	150/20	866	150	150	11.09.2013	19	22,2	10	678	78.290993	21	21	53	56

Keterangan :



PT PLN (PERSERO) P3B JB
APP SALATIGA

**LAPORAN BEBAN PUNCAK TRAFU GARDU INDUK
PT PLN (PERSERO) P3B APP SALATIGA
BULAN : Oktober 2013**

NO	GARDU INDUK	TRAFO			AMP NOM (A)	OCR Sett		BEBAN TERTINGGI							TEMPERATUR		
		NO	DAYA (MVA)	RATIO (KV)		A	KV	TGL	JAM	MW	MVAR	AMP INC	% In	Tegangan 20 KV		Winding	Oil
														TRD	TTI		
1	KLATEN	I	30	150/20	866	150	150	02.09.2013	19	23	10,2	740	85.450346	20.8	20.8	52	58
2	KLATEN	II	30	150/20	866	150	150	11.09.2013	19	22,2	10	678	78.290993	21	21	53	56

Keterangan :

**LAPORAN BEBAN PUNCAK TRAFO GARDU INDUK
PT PLN (PERSERO) P3B APP SALATIGA
BULAN : November 2013**

NO	GARDU INDUK	TRAFO			AMP NOM (A)	OCR Sett		BEBAN TERTINGGI							TEMPERATUR		
		NO	DAYA (MVA)	RATIO (KV)		A	KV	Tgl/Bl/Thn	JAM	MW	MVAR	AMP INC	% In	Tegangan 20 KV		Winding	Oil
														TRD	TTI		
1	KLATEN	I	30	150/20	866	150	150	11.11.2013	19	23,5	10,6	735	84.87	20.6	20.8	65	56
2	KLATEN	II	30	150/20	866	150	150	22.11.2013	19	22,9	10,3	705	81.41	21	21	64	65

Keterangan :

**LAPORAN BEBAN PUNCAK TRAFO GARDU INDUK
PT PLN (PERSERO) P3B APP SALATIGA
BULAN : Desember 2013**

NO	GARDU INDUK	TRAFO			AMP NOM (A)	OCR Sett		BEBAN TERTINGGI							TEMPERATUR		
		NO	DAYA (MVA)	RATIO (KV)		A	KV	Tgl/Bl/Thn	JAM	MW	MVAR	AMP INC	% In	Tegangan 20 KV		Winding	Oil
														TRD	TTI		
1	KLATEN	I	30	150/20	866	150	150	04.12.2013	19	23,9	10,6	731	84.41	20.6	20.8	63	56
2	KLATEN	II	30	150/20	866	150	150	04.12.2013	19	23,8	10,3	735	84.87	21	21	64	65

Keterangan :



PT PLN (PERSERO) P3B JB
APP SALATIGA

LAPORAN BEBAN PUNCAK TRAFU GARDU INDUK
PT PLN (PERSERO) P3B UPT SURAKARTA
BULAN : Januari 2014

NO	GARDU INDUK	TRAFO			AMP NOM (A)	OCR Sett		BEBAN TERTINGGI							TEMPERATUR		
		NO	DAYA (MVA)	RATIO (KV)		A	KV	TGL	JAM	MW	MVAR	AMP INC	% In	Tegangan 20 KV		Windin g	Oil
														TRD	TTI		
1	KLATEN	I	30	150/20	866	150	150	03.01.2014	19	23	9.9	755	87.182448	21	20.6	64	53
2	KLATEN	II	30	150/20	866	150	150	10.01.2014	19	23.6	10.2	661	76.327945	21	20.8	62	62

Keterangan :



PT PLN (PERSERO) P3B JB
APP SALATIGA

LAPORAN BEBAN PUNCAK TRAFU GARDU INDUK
PT PLN (PERSERO) P3B UPT SURAKARTA
BULAN : FEBRUARI 2014

NO	GARDU INDUK	TRAFO			AMP NOM (A)	OCR Sett		BEBAN TERTINGGI							TEMPERATUR		
		NO	DAYA (MVA)	RATIO (KV)		A	KV	TGL	JAM	MW	MVAR	AMP INC	% In	Tegangan 20 KV		Windin g	Oil
														TRD	TTI		
1	KLATEN	I	30	150/20	866	150	150	20.02.2014	19	21.7	9.1	760	87.759815	21	20.6	66	55
2	KLATEN	II	30	150/20	866	150	150	20.02.2014	19	23.5	10.8	651	75.17321	21	21	63	62

Keterangan :



PT PLN (PERSERO) P3B JB
APP SALATIGA

**LAPORAN BEBAN PUNCAK TRAFU GARDU INDUK
PT PLN (PERSERO) P3B UPT SURAKARTA
BULAN : MARET 2014**

NO	GARDU INDUK	TRAFO			AMP NOM (A)	OCR Sett		BEBAN TERTINGGI							TEMPERATUR		
		NO	DAYA (MVA)	RATIO (KV)		A	KV	TGL	JAM	MW	MVAR	AMP INC	% In	Tegangan 20 KV		Windin g	Oil
														TRD	TTI		
1	KLATEN	I	30	150/20	866	150	150	27.03.2014	19	22.1	9.4	760	87.759815	21	20.3	60	60
2	KLATEN	II	30	150/20	866	150	150	27.03.2014	19	25.3	11.6	630	72.748268	21	20.3	70	70

Keterangan :



PT PLN (PERSERO) P3B JB
APP SALATIGA

**LAPORAN BEBAN PUNCAK TRAFU GARDU INDUK
PT PLN (PERSERO) P3B APP SALATIGA
BULAN : APRI 2014**

NO	GARDU INDUK	TRAFO			AMP NOM (A)	OCR Sett		BEBAN TERTINGGI							TEMPERATUR		
		NO	DAYA (MVA)	RATIO (KV)		A	KV	TGL	JAM	MW	MVAR	AMP INC	% In	Tegangan 20 KV		Windin g	Oil
														TRD	TTI		
1	KLATEN	I	30	150/20	866	150	150	18.04.2014	19	24,3	11	775	89.491917	21	20.5	65	56
2	KLATEN	II	30	150/20	866	150	150	10.04.2014	19	24	9.8	641	74.018476	21	21	63	62

Keterangan :



PT PLN (PERSERO) P3B JB
APP SALATIGA

**LAPORAN BEBAN PUNCAK TRAFU GARDU INDUK
PT PLN (PERSERO) P3B APP SALATIGA
BULAN : MEI 2014**

NO	GARDU INDUK	TRAFO			AMP NOM (A)	OCR Sett		BEBAN TERTINGGI							TEMPERATUR		
		NO	DAYA (MVA)	RATIO (KV)		A	KV	TGL	JAM	MW	MVAR	AMP INC	% In	Tegangan 20 KV		Windin g	Oil
														TRD	TTI		
1	KLATEN	I	30	150/20	866	150	150	31.05.2014	19	24.3	8.6	735	84.872979	21	21	63	54
2	KLATEN	II	30	150/20	866	150	150	04.05.2014	19	24.6	10	619	71.47806	21	21	62	62

Keterangan :



PT PLN (PERSERO) P3B JB
APP SALATIGA

**LAPORAN BEBAN PUNCAK TRAFU GARDU INDUK
PT PLN (PERSERO) P3B APP SALATIGA
BULAN : JUNI 2014**

NO	GARDU INDUK	TRAFO			AMP NOM (A)	OCR Sett		BEBAN TERTINGGI							TEMPERATUR		
		NO	DAYA (MVA)	RATIO (KV)		A	KV	TGL	JAM	MW	MVAR	AMP INC	% In	Tegangan 20 KV		Windin g	Oil
														TRD	TTI		
1	KLATEN	I	30	150/20	866	150	150	20.06.2014	19	22.9	10.2	750	86.605081	21	20	66	56
2	KLATEN	II	30	150/20	866	150	150	21.06.2014	19	25.2	11.8	522	60.277136	21	20	60	60

Keterangan :



PT PLN (PERSERO) P3B JB
APP SALATIGA

**LAPORAN BEBAN PUNCAK TRAFU GARDU INDUK
PT PLN (PERSERO) P3B APP SALATIGA
BULAN : JULI 2014**

NO	GARDU INDUK	TRAFO			AMP NOM (A)	OCR Sett		BEBAN TERTINGGI							TEMPERATUR		
		NO	DAYA (MVA)	RATIO (KV)		A	KV	TGL	JAM	MW	MVAR	AMP INC	% In	Tegangan 20 KV		Windin g	Oil
														TRD	TTI		
1	KLATEN	I	30	150/20	866	150	150	20.07.2014	19	22.3	9.2	725	83.718245	20,7	20,7	61	51
2	KLATEN	II	30	150/20	866	150	150	16.07.2014	19	24.4	11.4	644	74.364896	21	21	57	57

Keterangan :



PT PLN (PERSERO) P3B JB
APP SALATIGA

**LAPORAN BEBAN PUNCAK TRAFU GARDU INDUK
PT PLN (PERSERO) P3B APP SALATIGA
BULAN : AGUSTUS 2014**

NO	GARDU INDUK	TRAFO			AMP NOM (A)	OCR Sett		BEBAN TERTINGGI							TEMPERATUR		
		NO	DAYA (MVA)	RATIO (KV)		A	KV	TGL	JAM	MW	MVAR	AMP INC	% In	Tegangan 20 KV		Windin g	Oil
														TRD	TTI		
1	KLATEN	I	30	150/20	866	150	150	13.08.2014	19	24.1	10.4	700	80.831409	20,7	20,7	60	50
2	KLATEN	II	30	150/20	866	150	150	10.08.2014	19	23.8	10	515	59.468822	21	21	60	60

Keterangan :



PT PLN (PERSERO) P3B JB
APP SALATIGA

**LAPORAN BEBAN PUNCAK TRAFU GARDU INDUK
PT PLN (PERSERO) P3B APP SALATIGA
BULAN : SEPTEMBER 2014**

NO	GARDU INDUK	TRAFO			AMP NOM (A)	OCR Sett		BEBAN TERTINGGI							TEMPERATUR		
		NO	DAYA (MVA)	RATIO (KV)		A	KV	TGL	JAM	MW	MVAR	AMP INC	% In	Tegangan 20 KV		Windin g	Oil
														TRD	TTI		
1	KLATEN	I	30	150/20	866	150	150	21.09.2014	19	24.4	10.5	705	81.408776	20,5	21	61	51
2	KLATEN	II	30	150/20	866	150	150	17.09.2014	19	25,3	9.7	508	58.660508	21	21	65	65

Keterangan :



PT PLN (PERSERO) P3B JB
APP SALATIGA

**LAPORAN BEBAN PUNCAK TRAFU GARDU INDUK
PT PLN (PERSERO) P3B APP SALATIGA
BULAN : OKTOBER 2014**

NO	GARDU INDUK	TRAFO			AMP NOM (A)	OCR Sett		BEBAN TERTINGGI							TEMPERATUR		
		NO	DAYA (MVA)	RATIO (KV)		A	KV	TGL	JAM	MW	MVAR	AMP INC	% In	Tegangan 20 KV		Windin g	Oil
														TRD	TTI		
1	KLATEN	I	30	150/20	866	150	150	09.10.2014	19	24.9	10.6	710	81.986143	20.7	20.7	65	54
2	KLATEN	II	30	150/20	866	150	150	30.10.2014	19	24.5	10.8	617	71.247113	21	21	65	65

Keterangan :



PT PLN (PERSERO) P3B JB
APP SALATIGA

**LAPORAN BEBAN PUNCAK TRAFU GARDU INDUK
PT PLN (PERSERO) P3B APP SALATIGA
BULAN : NOPEMBER 2014**

NO	GARDU INDUK	TRAFO			AMP NOM (A)	OCR Sett		BEBAN TERTINGGI								TEMPERATUR	
		NO	DAYA (MVA)	RATIO (KV)		A	KV	TGL	JAM	MW	MVAR	AMP INC	% In	Tegangan 20 KV		Windin g	Oil
														TRD	TTI		
1	KLATEN	I	30	150/20	866	150	150	09.11.2014	19	24.9	10.8	725	83.718245	20.7	20.7	64	53
2	KLATEN	II	30	150/20	866	150	150	09.11.2014	19	24.5	10.6	553	63.856813	21	20.7	58	58

Keterangan :



PT PLN (PERSERO) P3B JB
APP SALATIGA

**LAPORAN BEBAN PUNCAK TRAFU GARDU INDUK
PT PLN (PERSERO) P3B APP SALATIGA
BULAN : DESEMBER 2014**

NO	GARDU INDUK	TRAFO			AMP NOM (A)	OCR Sett		BEBAN TERTINGGI								TEMPERATUR	
		NO	DAYA (MVA)	RATIO (KV)		A	KV	TGL	JAM	MW	MVAR	AMP INC	% In	Tegangan 20 KV		Windin g	Oil
														TRD	TTI		
1	KLATEN	I	30	150/20	866	150	150	09.11.2014	19	24	9.2	725	83.718245	20.7	20.7	64	53
2	KLATEN	II	30	150/20	866	150	150	09.11.2014	19	23.9	10.5	553	63.856813	21	20.7	58	58

Keterangan :



PT PLN (PERSERO) P3B JB
APP SALATIGA

**LAPORAN BEBAN PUNCAK TRAFO GARDU INDUK
PT PLN (PERSERO) P3B APP SALATIGA
BULAN : JANUARI 2015**

NO	GARDU INDUK	TRAFO			AMP NOM (A)	OCR Sett		BEBAN TERTINGGI								TEMPERATUR	
		NO	DAYA (MVA)	RATIO (KV)		A	KV	TGL	JAM	MW	MVAR	AMP INC	% In	Tegangan 20 KV		Winding	Oil
														TRD	TTI		
1	KLATEN	I	30	150/20	866	150	150	31.01.2015	19	22.9	9	716	82.678984	20.7	20	61	51
2	KLATEN	II	30	150/20	866	150	150	19.01.2015	19	23.4	10.5	527	60.854503	21	20	59	59

Keterangan :



PT PLN (PERSERO) P3B JB
APP SALATIGA

**LAPORAN BEBAN PUNCAK TRAFO GARDU INDUK
PT PLN (PERSERO) P3B APP SALATIGA
BULAN : FEBRUARI 2015**

NO	GARDU INDUK	TRAFO			AMP NOM (A)	OCR Sett		BEBAN TERTINGGI								TEMPERATUR	
		NO	DAYA (MVA)	RATIO (KV)		A	KV	TGL	JAM	MW	MVAR	AMP INC	% In	Tegangan 20 KV		Winding	Oil
														TRD	TTI		
1	KLATEN	I	30	150/20	866	150	150	11.02.2015	19	22.9	9.2	727	83.949192	20.7	20.5	61	52
2	KLATEN	II	30	150/20	866	150	150	26.02.2015	19	23.7	10.3	614	70.900693	21	21	65	65

Keterangan :



PT PLN (PERSERO) P3B JB
APP SALATIGA

**LAPORAN BEBAN PUNCAK TRAFO GARDU INDUK
PT PLN (PERSERO) P3B APP SALATIGA
BULAN : MARET 2015**

NO	GARDU INDUK	TRAFO			AMP NOM (A)	OCR Sett		BEBAN TERTINGGI								TEMPERATUR	
		NO	DAYA (MVA)	RATIO (KV)		A	KV	TGL	JAM	MW	MVAR	AMP INC	% In	Tegangan 20 KV		Winding	Oil
														TRD	TTI		
1	KLATEN	I	30	150/20	866	150	150	06.03.2015	19	23.8	9.6	742	85.681293	20.7	20.7	61	53
2	KLATEN	II	30	150/20	866	150	150	22.03.2015	19	25.2	10.8	654	75.51963	21	21	62	62

Keterangan :



PT PLN (PERSERO) P3B JB
APP SALATIGA

**LAPORAN BEBAN PUNCAK TRAFO GARDU INDUK
PT PLN (PERSERO) P3B APP SALATIGA
BULAN : APRIL 2015**

NO	GARDU INDUK	TRAFO			AMP NOM (A)	OCR Sett		BEBAN TERTINGGI								TEMPERATUR	
		NO	DAYA (MVA)	RATIO (KV)		A	KV	TGL	JAM	MW	MVAR	AMP INC	% In	Tegangan 20 KV		Winding	Oil
														TRD	TTI		
1	KLATEN	I	30	150/20	866	150	150	30.04.2015	19	23.9	9.5	726	83.833718	20.7	20.7	63	53
2	KLATEN	II	30	150/20	866	150	150	26.04.2015	19	24.5	10.5	663	76.558891	21	21	65	65

Keterangan :



PT PLN (PERSERO) P3B JB
APP SALATIGA

**LAPORAN BEBAN PUNCAK TRAFU GARDU INDUK
PT PLN (PERSERO) P3B APP SALATIGA
BULAN : MEI 2015**

NO	GARDU INDUK	TRAFO			AMP NOM (A)	OCR Sett		BEBAN TERTINGGI							TEMPERATUR		
		NO	DAYA (MVA)	RATIO (KV)		A	KV	TGL	JAM	MW	MVAR	AMP INC	% In	Tegangan 20 KV		Winding	Oil
														TRD	TTI		
1	KLATEN	I	30	150/20	866	150	150	07.05.2015	19	23.2	9.2	763	88.106236	20.7	20.7	66	57
2	KLATEN	II	30	150/20	866	150	150	03.05.2015	19	24.7	11.1	660	76.212471	21	21	72	72

Keterangan :



PT PLN (PERSERO) P3B JB
APP SALATIGA

**LAPORAN BEBAN PUNCAK TRAFU GARDU INDUK
PT PLN (PERSERO) P3B APP SALATIGA
BULAN : JUNI 2015**

NO	GARDU INDUK	TRAFO			AMP NOM (A)	OCR Sett		BEBAN TERTINGGI							TEMPERATUR		
		NO	DAYA (MVA)	RATIO (KV)		A	KV	TGL	JAM	MW	MVAR	AMP INC	% In	Tegangan 20 KV		Winding	Oil
														TRD	TTI		
1	KLATEN	I	30	150/20	866	150	150	28.06.2015	19	23.4	9.4	732	84.526559	20.6	20.6	52	59
2	KLATEN	II	30	150/20	866	150	150	18.06.2015	19	24.2	10.6	636	73.441109	21	21	60	60

Keterangan :

**LAPORAN BEBAN PUNCAK TRAFO GARDU INDUK
PT PLN (PERSERO) P3B APP SALATIGA
BULAN : JULI 2015**

NO	GARDU INDUK	TRAFO			AMP NOM (A)	OCR Sett		BEBAN TERTINGGI							TEMPERATUR		
		NO	DAYA (MVA)	RATIO (KV)		A	KV	TGL	JAM	MW	MVAR	AMP INC	% In	Tegangan 20 KV		Winding	Oil
														TRD	TTI		
1	KLATEN	I	30	150/20	866	150	150	22.07.2015	19	23.2	9.1	734	84.757506	20.8	20.8	61	59
2	KLATEN	II	30	150/20	866	150	150	26.07.2015	19	25.4	11.4	660	76.212471	21	21	61	60

Keterangan :

**LAPORAN BEBAN PUNCAK TRAFO GARDU INDUK
PT PLN (PERSERO) P3B APP SALATIGA
BULAN : AGUSTUS 2015**

NO	GARDU INDUK	TRAFO			AMP NOM (A)	OCR Sett		BEBAN TERTINGGI							TEMPERATUR		
		NO	DAYA (MVA)	RATIO (KV)		A	KV	TGL	JAM	MW	MVAR	AMP INC	% In	Tegangan 20 KV		Winding	Oil
														TRD	TTI		
1	KLATEN	I	30	150/20	866	150	150	30.08.2015	19	23.2	9.1	734	84.757506	20.8	20.8	52	57
2	KLATEN	II	30	150/20	866	150	150	31.07.2015	19	24.9	11	668	77.136259	21	21	62	62

Keterangan :



PT PLN (PERSERO) P3B JB
APP SALATIGA

**LAPORAN BEBAN PUNCAK TRAFU GARDU INDUK
PT PLN (PERSERO) P3B APP SALATIGA
BULAN : SEPTEMBER 2015**

NO	GARDU INDUK	TRAFO			AMP NOM (A)	OCR Sett		BEBAN TERTINGGI							TEMPERATUR		
		NO	DAYA (MVA)	RATIO (KV)		A	KV	TGL	JAM	MW	MVAR	AMP INC	% In	Tegangan 20 KV		Winding	Oil
														TRD	TTI		
1	KLATEN	I	30	150/20	866	150	150	02.09.2015	19	24.1	9.6	740	85.450346	20.8	20.8	52	58
2	KLATEN	II	30	150/20	866	150	150	11.09.2015	19	25	11.3	678	78.290993	21	21	53	56

Keterangan :



PT PLN (PERSERO) P3B JB
APP SALATIGA

**LAPORAN BEBAN PUNCAK TRAFU GARDU INDUK
PT PLN (PERSERO) P3B APP SALATIGA
BULAN : Oktober 2015**

NO	GARDU INDUK	TRAFO			AMP NOM (A)	OCR Sett		BEBAN TERTINGGI							TEMPERATUR		
		NO	DAYA (MVA)	RATIO (KV)		A	KV	TGL	JAM	MW	MVAR	AMP INC	% In	Tegangan 20 KV		Winding	Oil
														TRD	TTI		
1	KLATEN	I	30	150/20	866	150	150	02.09.2015	19	24	9.6	740	85.450346	20.8	20.8	52	58
2	KLATEN	II	30	150/20	866	150	150	11.09.2015	19	24.8	11.3	678	78.290993	21	21	53	56

Keterangan :



PT PLN (PERSERO) P3B JB
APP SALATIGA

LAPORAN BEBAN PUNCAK TRAFU GARDU INDUK
PT PLN (PERSERO) P3B APP SALATIGA
BULAN : November 2015

NO	GARDU INDUK	TRAFO			AMP NOM (A)	OCR Sett		BEBAN TERTINGGI							TEMPERATUR		
		NO	DAYA (MVA)	RATIO (KV)		A	KV	Tgl/Bl/Thn	JAM	MW	MVAR	AMP INC	% In	Tegangan 20 KV		Winding	Oil
														TRD	TTI		
1	KLATEN	I	30	150/20	866	150	150	11.11.2015	19	25.4	9.3	735	84.87	20.6	20.8	65	56
2	KLATEN	II	30	150/20	866	150	150	22.11.2015	19	25.6	11	705	81.41	21	21	64	65

Keterangan :



PT PLN (PERSERO) P3B JB
APP SALATIGA

LAPORAN BEBAN PUNCAK TRAFU GARDU INDUK
PT PLN (PERSERO) P3B APP SALATIGA
BULAN : Desember 2015

NO	GARDU INDUK	TRAFO			AMP NOM (A)	OCR Sett		BEBAN TERTINGGI							TEMPERATUR		
		NO	DAYA (MVA)	RATIO (KV)		A	KV	Tgl/Bl/Thn	JAM	MW	MVAR	AMP INC	% In	Tegangan 20 KV		Winding	Oil
														TRD	TTI		
1	KLATEN	I	30	150/20	866	150	150	04.12.2015	19	22.8	9.2	731	84.41	20.6	20.8	63	56
2	KLATEN	II	30	150/20	866	150	150	04.12.2015	19	25.3	10.6	735	84.87	21	21	64	65

Keterangan :



PT PLN (PERSERO) P3B JB
APP SALATIGA

LAPORAN BEBAN PUNCAK TRAFU GARDU INDUK
PT PLN (PERSERO) P3B UPT SURAKARTA
BULAN : Januari 2016

NO	GARDU INDUK	TRAFO			AMP NOM (A)	OCR Sett		BEBAN TERTINGGI							TEMPERATUR		
		NO	DAYA (MVA)	RATIO (KV)		A	KV	TGL	JAM	MW	MVAR	AMP INC	% In	Tegangan 20 KV		Windin g	Oil
														TRD	TTI		
1	KLATEN	I	30	150/20	866	150	150	11.01.2016	19	22.3	9.1	755	87.182448	21	20.6	64	53
2	KLATEN	II	30	150/20	866	150	150	27.01.2016	19	25.3	11.2	661	76.327945	21	20.8	62	62

Keterangan :



PT PLN (PERSERO) P3B JB
APP SALATIGA

LAPORAN BEBAN PUNCAK TRAFU GARDU INDUK
PT PLN (PERSERO) P3B UPT SURAKARTA
BULAN : FEBRUARI 2016

NO	GARDU INDUK	TRAFO			AMP NOM (A)	OCR Sett		BEBAN TERTINGGI							TEMPERATUR		
		NO	DAYA (MVA)	RATIO (KV)		A	KV	TGL	JAM	MW	MVAR	AMP INC	% In	Tegangan 20 KV		Windin g	Oil
														TRD	TTI		
1	KLATEN	I	30	150/20	866	150	150	09.02.2016	19	22.7	8.7	760	87.759815	21	20.6	66	55
2	KLATEN	II	30	150/20	866	150	150	10.02.2016	19	24.7	10.2	651	75.17321	21	21	63	62

Keterangan :



PT PLN (PERSERO) P3B JB
APP SALATIGA

**LAPORAN BEBAN PUNCAK TRAFU GARDU INDUK
PT PLN (PERSERO) P3B UPT SURAKARTA
BULAN : MARET 2016**

NO	GARDU INDUK	TRAFO			AMP NOM (A)	OCR Sett		BEBAN TERTINGGI							TEMPERATUR		
		NO	DAYA (MVA)	RATIO (KV)		A	KV	TGL	JAM	MW	MVAR	AMP INC	% In	Tegangan 20 KV		Windin g	Oil
														TRD	TTI		
1	KLATEN	I	30	150/20	866	150	150	27.03.2016	19	24.5	9.6	760	87.759815	21	20.3	63	52
2	KLATEN	II	30	150/20	866	150	150	27.03.2016	19	24.5	10	630	72.748268	21	20.3	60	60

Keterangan :



PT PLN (PERSERO) P3B JB
APP SALATIGA

**LAPORAN BEBAN PUNCAK TRAFU GARDU INDUK
PT PLN (PERSERO) P3B APP SALATIGA
BULAN : APRI 2016**

NO	GARDU INDUK	TRAFO			AMP NOM (A)	OCR Sett		BEBAN TERTINGGI							TEMPERATUR		
		NO	DAYA (MVA)	RATIO (KV)		A	KV	TGL	JAM	MW	MVAR	AMP INC	% In	Tegangan 20 KV		Windin g	Oil
														TRD	TTI		
1	KLATEN	I	30	150/20	866	150	150	18.04.2016	19	23.9	9.3	775	89.491917	21	20.5	65	53
2	KLATEN	II	30	150/20	866	150	150	10.04.2016	19	25.2	7.8	641	74.018476	21	21	65	65

Keterangan :



PT PLN (PERSERO) P3B JB
APP SALATIGA

**LAPORAN BEBAN PUNCAK TRAFU GARDU INDUK
PT PLN (PERSERO) P3B APP SALATIGA
BULAN : MEI 2016**

NO	GARDU INDUK	TRAFO			AMP NOM (A)	OCR Sett		BEBAN TERTINGGI							TEMPERATUR		
		NO	DAYA (MVA)	RATIO (KV)		A	KV	TGL	JAM	MW	MVAR	AMP INC	% In	Tegangan 20 KV		Windin g	Oil
														TRD	TTI		
1	KLATEN	I	30	150/20	866	150	150	31.05.2016	19	24	9.2	735	84.872979	21	21	63	54
2	KLATEN	II	30	150/20	866	150	150	04.05.2016	19	24.2	9.8	619	71.47806	21	21	62	62

Keterangan :



PT PLN (PERSERO) P3B JB
APP SALATIGA

**LAPORAN BEBAN PUNCAK TRAFU GARDU INDUK
PT PLN (PERSERO) P3B APP SALATIGA
BULAN : JUNI 2016**

NO	GARDU INDUK	TRAFO			AMP NOM (A)	OCR Sett		BEBAN TERTINGGI							TEMPERATUR		
		NO	DAYA (MVA)	RATIO (KV)		A	KV	TGL	JAM	MW	MVAR	AMP INC	% In	Tegangan 20 KV		Windin g	Oil
														TRD	TTI		
1	KLATEN	I	30	150/20	866	150	150	20.06.2016	19	23.7	8.2	750	86.605081	21	20	66	56
2	KLATEN	II	30	150/20	866	150	150	21.06.2016	19	24.1	10.1	522	60.277136	21	20	60	60

Keterangan :



PT PLN (PERSERO) P3B JB
APP SALATIGA

LAPORAN BEBAN PUNCAK TRAFU GARDU INDUK
PT PLN (PERSERO) P3B APP SALATIGA
BULAN : JULI 2016

NO	GARDU INDUK	TRAFO			AMP NOM (A)	OCR Sett		BEBAN TERTINGGI							TEMPERATUR		
		NO	DAYA (MVA)	RATIO (KV)		A	KV	TGL	JAM	MW	MVAR	AMP INC	% In	Tegangan 20 KV		Windin g	Oil
														TRD	TTI		
1	KLATEN	I	30	150/20	866	150	150	20.07.2016	19	23.4	8.8	725	83.718245	20,7	20,7	61	51
2	KLATEN	II	30	150/20	866	150	150	16.07.2016	19	23.8	8.7	644	74.364896	21	21	57	57

Keterangan :



PT PLN (PERSERO) P3B JB
APP SALATIGA

LAPORAN BEBAN PUNCAK TRAFU GARDU INDUK
PT PLN (PERSERO) P3B APP SALATIGA
BULAN : AGUSTUS 2016

NO	GARDU INDUK	TRAFO			AMP NOM (A)	OCR Sett		BEBAN TERTINGGI							TEMPERATUR		
		NO	DAYA (MVA)	RATIO (KV)		A	KV	TGL	JAM	MW	MVAR	AMP INC	% In	Tegangan 20 KV		Windin g	Oil
														TRD	TTI		
1	KLATEN	I	30	150/20	866	150	150	13.08.2016	19	23.6	8.8	700	80.831409	20,7	20,7	60	50
2	KLATEN	II	30	150/20	866	150	150	10.08.2016	19	24.2	9.8	515	59.468822	21	21	60	60

Keterangan :



PT PLN (PERSERO) P3B JB
APP SALATIGA

**LAPORAN BEBAN PUNCAK TRAFU GARDU INDUK
PT PLN (PERSERO) P3B APP SALATIGA
BULAN : SEPTEMBER 2016**

NO	GARDU INDUK	TRAFO			AMP NOM (A)	OCR Sett		BEBAN TERTINGGI								TEMPERATUR	
		NO	DAYA (MVA)	RATIO (KV)		A	KV	TGL	JAM	MW	MVAR	AMP INC	% In	Tegangan 20 KV		Windin g	Oil
														TRD	TTI		
1	KLATEN	I	30	150/20	866	150	150	21.09.2016	19	23.5	9	705	81.408776	20,5	21	61	51
2	KLATEN	II	30	150/20	866	150	150	17.09.2016	19	23.5	9	508	58.660508	21	21	65	65

Keterangan :



PT PLN (PERSERO) P3B JB
APP SALATIGA

**LAPORAN BEBAN PUNCAK TRAFU GARDU INDUK
PT PLN (PERSERO) P3B APP SALATIGA
BULAN : OKTOBER 2016**

NO	GARDU INDUK	TRAFO			AMP NOM (A)	OCR Sett		BEBAN TERTINGGI								TEMPERATUR	
		NO	DAYA (MVA)	RATIO (KV)		A	KV	TGL	JAM	MW	MVAR	AMP INC	% In	Tegangan 20 KV		Windin g	Oil
														TRD	TTI		
1	KLATEN	I	30	150/20	866	150	150	09.10.2016	19	23.5	8.7	710	81.986143	20.7	20.7	65	54
2	KLATEN	II	30	150/20	866	150	150	30.10.2016	19	23.5	8.7	617	71.247113	21	21	65	65

Keterangan :



PT PLN (PERSERO) P3B JB
APP SALATIGA

**LAPORAN BEBAN PUNCAK TRAFU GARDU INDUK
PT PLN (PERSERO) P3B APP SALATIGA
BULAN : NOPEMBER 2016**

NO	GARDU INDUK	TRAFO			AMP NOM (A)	OCR Sett		BEBAN TERTINGGI								TEMPERATUR	
		NO	DAYA (MVA)	RATIO (KV)		A	KV	TGL	JAM	MW	MVAR	AMP INC	% In	Tegangan 20 KV		Windin g	Oil
														TRD	TTI		
1	KLATEN	I	30	150/20	866	150	150	09.11.2016	19	23.2	8.2	725	83.718245	20.7	20.7	64	53
2	KLATEN	II	30	150/20	866	150	150	09.11.2016	19	25.5	9.8	553	63.856813	21	20.7	58	58

Keterangan :



PT PLN (PERSERO) P3B JB
APP SALATIGA

**LAPORAN BEBAN PUNCAK TRAFU GARDU INDUK
PT PLN (PERSERO) P3B APP SALATIGA
BULAN : DESEMBER 2016**

NO	GARDU INDUK	TRAFO			AMP NOM (A)	OCR Sett		BEBAN TERTINGGI								TEMPERATUR	
		NO	DAYA (MVA)	RATIO (KV)		A	KV	TGL	JAM	MW	MVAR	AMP INC	% In	Tegangan 20 KV		Windin g	Oil
														TRD	TTI		
1	KLATEN	I	30	150/20	866	150	150	09.11.2016	19	22.3	8	725	83.718245	20.7	20.7	64	53
2	KLATEN	II	30	150/20	866	150	150	09.11.2016	19	19.2	6.4	553	63.856813	21	20.7	58	58

Keterangan :

