



GANGGUAN TRAFU TENAGA GARDU INDUK 150 kV BANTUL 2013-2018

GI 150 kV BANTUL TRAFU 1

No	Kejadian		Jenis Gangguan	Annaunciaror	Rele Proteksi &indikasi	Beban				Penormalan		Keeran gan
	Tanggal	Jam				KV	A	MW	MVAR	Tanggal	Jam	
1	03/04/2013	15.24	PMT 150 Kv trip PMT INC 20 Kv trip	Pressure relief Tranformator Trip	Lock Out	150 20.6	-129 -856	-28 -28	-9 -9	03/04/2013	10.00	Kabel Sudden pressure yang berada didekat Kabel kontrol Tap 13 & 14 bocor.
2	18/03/2013	15.19	PMT incoming Trafo 1 trip	OCR TD OCR GFR instant	Trip - Phasa A OCR/GFR Instant	150	888	30	10	17/03/2013	19.00	Socket PMT BNL 1 Menyentuh Support pmt dan pms BNL 1

3	20/03/2016	19.52	Over Load (OL)	-PMT 150 KV trip - PMT 20 KV trip		150	120	8,22	17,3	20/03/2016	22.50	Maneuver pararel
4	25/09/2017	03.30	Short Circuit Fedder	-OCR EF trip -UVR alarm -AVR rele blocked -20 KV REF oprating	-PMT 20 kV Trip _PMT feeder Close	150	-	-	25	25/09/2017	17.00	Gangguan



PT PLN (PERSERO) P3B JB
UNIT PELAYANAN TRANSMISI YOGYAKARTA
Jl. Parangtritis, Km 5 No 6 Yogyakarta

GI 150 kV BANTUL TRAFU 2

No	Kejadian		Jenis Gangguan	Annaunciaror	Rele Proteksi & indikasi	Beban				Penormalan		Keerangan
	Tanggal	Jam				KV	A	MW	MVAR	Tanggal	Jam	
1	05/06/2014	06.28	IMCOMING 1 Trip	OCR (1)	- OCR (1)	150	750	-	-	05/06/2014	15.35	BNL 5 ada Gangguan OCR & GFR Tetapi PMT Feeder tidak Mau TRIP
2	22/07/2015	08.45	PMT20 KV incoming trafo 2 trip	REF 150/20	- PMT 20 KV TRIP	150	135	7,45	16,5	22/07/2015	14.00	Signal trip feeder Bantul 2

3	9/08/2016	09.57	PMT 20KV incoming trafo 2 trifp	Buy incoming trafo 2 OCR time delay	OCR delay	150	145	9,24	11,3	9/08/2015	20.15	Maneuver pararel
---	-----------	-------	---------------------------------------	---	-----------	-----	-----	------	------	-----------	-------	---------------------