

LAMPIRAN

Data Operasi Harian 25 Januari 2019

Waktu	Vout Generator (kV)	Daya Aktif (MW)	Daya Reaktif (MVAR)	Arus Jangkar (A)	Arus Eksitasi (A)	Debit Air (m ³ /detik)
00:00	13.98	58.08	10.00	2436.81	949.24	69.83
01:00	13.97	58.00	9.89	2442.53	949.08	69.88
02:00	13.99	58.98	10.01	2497.47	966.64	70.44
03:00	13.85	59.18	5.32	2509.09	917.11	70.34
04:00	13.86	59.12	5.36	2492.65	917.08	70.02
05:00	13.77	59.42	5.99	2507.63	919.48	70.05
06:00	13.69	59.44	4.78	2518.65	905.05	69.91
07:00	13.82	59.04	5.37	2505.45	911.02	69.63
08:00	13.58	59.37	5.50	2540.60	907.64	69.70
09:00	14.09	58.87	19.91	2570.97	1055.24	69.52
10:00	14.04	58.95	20.34	2572.87	1062.90	69.74
11:00	14.00	58.94	20.33	2591.72	1055.24	69.78
12:00	14.19	59.17	19.94	2553.66	1065.42	69.77
13:00	14.00	58.90	18.78	2560.71	1037.83	69.33
14:00	13.88	59.08	18.44	2595.53	1035.24	69.97
15:00	13.92	58.88	17.96	2580.13	1033.17	69.67
16:00	13.99	58.93	18.20	2538.80	1033.11	69.19
17:00	14.07	59.26	18.14	2535.08	1037.79	69.65
18:00	14.09	58.98	17.67	2537.18	1028.24	70.00
19:00	14.15	59.10	18.81	2541.79	1045.64	69.95
20:00	14.17	57.46	18.32	2473.69	1033.02	68.93
21:00	14.22	57.61	18.40	2467.43	1037.73	69.35
22:00	14.22	59.03	18.33	2517.55	1045.49	69.67
23:00	14.27	59.21	19.10	2530.79	1055.37	69.81

Data Operasi Harian 26 Januari 2019

Waktu	Vout Generator (kV)	Daya Aktif (MW)	Daya Reaktif (MVAR)	Arus Jangkar (A)	Arus Eksitasi (A)	Debit Air (m ³ /detik)
00:00	14.19	58.90	18.83	2480.61	1015.77	69.44
01:00	14.01	59.11	12.10	2499.63	976.36	69.63
02:00	14.05	59.08	12.21	2496.10	986.52	69.78
03:00	14.10	59.26	12.23	2481.09	986.27	69.67
04:00	14.12	59.10	12.44	2482.07	986.36	69.89
05:00	13.96	59.01	11.38	2490.19	968.98	69.45
06:00	13.92	59.30	13.03	2516.52	981.30	69.82
07:00	14.10	59.31	14.04	2498.72	1005.93	69.50
08:00	13.97	59.04	14.66	2524.57	1003.58	69.72
09:00	13.86	59.29	13.87	2556.02	996.08	70.20
10:00	13.86	58.92	14.18	2541.74	995.92	70.02
11:00	14.04	58.70	18.49	2548.49	1037.89	69.60
12:00	14.04	58.87	14.66	2499.23	995.61	69.22
13:00	14.04	58.57	14.82	2516.09	1013.23	69.39
14:00	14.00	58.39	15.33	2507.24	1006.08	69.35
15:00	14.04	58.65	15.07	2509.01	1006.36	70.05
16:00	14.10	58.60	15.71	2492.89	1013.52	69.41
17:00	14.06	58.79	12.22	2470.43	976.17	69.28
18:00	13.95	59.07	12.49	2513.91	976.39	69.71
19:00	13.87	59.01	12.69	2510.37	976.39	69.20
20:00	13.90	59.02	12.47	2537.04	976.42	69.53
21:00	13.96	58.93	11.91	2513.50	976.33	69.67
22:00	13.99	59.08	11.94	2496.56	976.30	69.66
23:00	14.05	58.84	12.43	2478.53	976.05	69.40

Data Operasi Harian 27 Januari 2019

Waktu	Vout Generator (kV)	Daya Aktif (MW)	Daya Reaktif (MVAR)	Arus Jangkar (A)	Arus Eksitasi (A)	Debit Air (m ³ /detik)
00:00	14.06	58.77	11.88	2464.87	976.33	69.30
01:00	14.07	58.98	10.61	2467.95	966.42	69.80
02:00	14.10	58.36	10.42	2461.96	966.77	69.56
03:00	14.12	58.70	10.51	2463.52	973.93	69.76
04:00	14.13	58.63	10.33	2442.36	966.61	69.33
05:00	14.03	58.86	10.55	2478.14	966.45	69.51
06:00	13.92	58.55	8.61	2480.97	944.46	69.62
07:00	13.94	58.67	9.13	2469.95	946.80	69.66
08:00	13.82	58.73	9.52	2500.12	946.70	69.54
09:00	13.77	59.08	9.06	2502.89	939.74	69.33
10:00	13.86	57.30	9.44	2517.43	946.80	69.60
11:00	14.04	35.29	11.54	2445.38	958.67	67.81
12:00	14.02	57.34	12.73	1555.93	865.46	41.53
13:00	13.97	57.33	12.93	2433.83	976.24	67.90
14:00	13.98	58.68	11.74	2451.56	966.42	67.85
15:00	14.00	58.61	11.38	2473.80	974.08	69.07
16:00	14.00	58.66	12.23	2471.01	976.58	69.38
17:00	13.79	58.49	13.07	2481.77	986.36	69.32
18:00	13.73	58.66	12.19	2516.61	966.49	69.43
19:00	13.79	58.38	11.93	2528.22	966.33	69.63
20:00	14.11	58.31	13.55	2520.87	983.86	69.68
21:00	14.32	58.64	20.10	2537.49	1045.36	69.02
22:00	14.18	58.22	20.19	2505.91	1006.05	69.44
23:00	14.17	58.19	20.16	2466.85	1007.15	68.80